

CENTRAL POWER RESEARCH INSTITUTE

Switchgear Testing & Development Station
Govindpura, Bhopal- 23
SUPPLEMENTARY TEST LABORATORY
PROVISIONAL TEST REPORT

Test Report No. & Date : 2013/STL/1729 **21 NOV 2013**

Customer his reference and address : M/s Khokhar Electricals Pvt. Ltd.,
C-44, Sector-63, Noida.

Manufacturer, his reference & address : M/s Khokhar Electricals Pvt. Ltd.,
C-44, Sector-63, Noida.

Particulars of apparatus tested : 415V, 32 A, Electrical Panel
Designation : Nil
Type : Nil
Identification No./Sample code No. : STDSSTL13S1259
Sl.No. : KEPL:1232/01
Drawing No. (Under revision) : KEPL:1232/01 Rev -
Date (s) of test (s) : 18.11.2013 & 19.11.2013
No.of samples tested : One
Test conducted : Degree of Protection IP-52 (Category -1)

Particulars of test conducted : The above test was conducted on the
sample as per standard. No traces of powder observed inside the sample after IP5X test and no
traces of water observed inside the sample after IP-X5 test.

Test in accordance with standard/ : IS/IEC: 60947-1, 2004.
specifications

Customer's requirement/deviations if any : Nil

Name of the Witnessing person

Customer's representative : Mr. Rajinder Singh, General Manager

Other than Customer's representative : Nil


TEST ENGINEER

Note:

- This is only a provisional report. The final test report along with drawings and other documents will be issued separately.
- The results are not binding on the testing authority until the final test report is issued.
- Corrections/erasing invalidate the test report.


JOINT DIRECTOR

संयुक्त निदेशक

Joint Director

केन्द्रीय विद्युत अनुसन्धान संस्थान
Central Power Research Institute
स्वचालित परीक्षण तथा विकास केन्द्र
Switchgear Testing & Development
गोविन्दपुरा भोपाल - 462023
Govindpura Bhopal 462 023