

CENTRAL POWER RESEARCH INSTITUTE

Switchgear Testing & Development Station

Govindpura, Bhopal- 23

SUPPLEMENTARY TEST LABORATORY

PROVISIONAL TEST REPORT

Test Report No. & Date : 2013/STL/1731 **21 NOV 2013**

Customer his reference and address : M/s Khokhar Electricals Pvt. Ltd.,
C-44, Sector-63, Noida.

Manufacturer, his reference & address : M/s Khokhar Electricals Pvt. Ltd.,
C-44, Sector-63, Noida.

Particulars of apparatus tested : 415V, 32 A, Electrical Panel

Designation : Nil

Type : Nil

Identification No./Sample code No. : STDSSSTL13S1261

Sl. No. : KEPL:1234/01

Drawing No. (Under revision) : KEPL:1234/01 Rev -

Date (s) of test (s) : 19.11.2013 & 20.11.2013

No.of samples tested : One

Test conducted : Degree of Protection IP-65

Particulars of test conducted : The above test was conducted on the sample as per standard. No traces of powder observed inside the sample after IP6X test and no traces of water observed inside the sample after IP-X5 test.

Test in accordance with standard/ specifications : IS/IEC: 60947-1, 2004.

Customer's requirement/deviations if any : Nil

Name of the Witnessing person

Customer's representative : Mr. Rajinder Singh, General Manager

Other than Customer's representative : Nil


TEST ENGINEER

Note:

- This is only a provisional report. The final test report along with drawings and other documents will be issued separately.
- The results are not binding on the testing authority until the final test report is issued.
- Corrections/erasing invalidate the test report.


JOINT DIRECTOR
संयुक्त निदेशक
Joint Director

केन्द्रीय शक्ति अनुसन्धान संस्थान
Central Power Research Institute
स्विचगियर परीक्षण तथा विकास केन्द्र
Switchgear Testing & Development
गोविन्दपुरा भोपाल - 462023
Govindpura Bhopal 462 023