Government of India MINISTRY OF ENERGY (Department of Power)

CENTRAL POWER RESEARCH INSTITUTE

GOVINDPURA BHOPAL -23

TEST REPORT

Report No.

: 89/STN II/241

Serial No.-

Client

: M/s Khokhar Electricals Pvt. Ltd., Delhi.

Manufacturer

* M/s Khokhar Electricals Pvt. Ltd., Delhi.

Apparatus

: Motor Control Centre

Type

: Draw out.

Rating assigned by the Manufacturer

> Rated Voltage Rated Current Frequency No. of phases Insulation level

: 500 V : 500 A : 50 Hz. : Three : 660 V

Rated Short time current: Dynamic - 94.5 KApk
Thermal - 45 KArms for 1 sec.

The tests done in

accordance with

: Clause No. 8.2.3 of IS : 8623, 1977.

Date of tests

:3rd August, 1989

Remarks regarding

performance

The performance of the equipment for the test

conducted is considered SATISFACTORY.

Any other remarks : Nil

This test report comprises of

THREE Sheets

FOUR I

Drawings

O N E Test circuit diagram T W O Oscillograms & O N E Photograph.

The second to th

Copyright: Publication or reproduction of the contents of this report in any form other than by a facsimile process is not allowed.

Issued on : 29/9 [1989

Engineering Officer Gr. IV Central Power Research Institute,

Goviadoura, BHOPAL